

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Thermal Overload Relays
Name and address of the applicant	Zhejiang Tengen Electric Co.,Ltd. Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China
Name and address of the manufacturer	Zhejiang Tengen Electric Co.,Ltd. Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China
Name and address of the factory	Zhejiang Tengen Electric Co.,Ltd. No.288 Central Avenue, Development Zone, Yueqing City, Zhejiang Province, P.R.China
<i>Note: When more than one factory, please report on page 2</i>	
Ratings and principal characteristics	Uimp:8kV; Ui:690V; Ue:AC690V; Ie:23-32A,30-40A,37-50A,48-65A,55-70A,63-80A,80-93A; Tripping class:10A; 3P; IP20; Auxiliary contact:(body contact):1NO1NC; Ith:5A;AC-15:380V/1.58A, 220V/2.73A
Trademark (if any)	TENGEN
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	JR28-93
Additional information (if necessary may also be reported on page 2)	
A sample of the product was tested and found to be in conformity with	IEC 60947-4-1:2018
As shown in the Test Report Ref. No. which forms part of this Certificate	00901-CB2019CQC-089259


This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>



Date: Dec.30,2019

Signature: 
Lu Mei